

Warranty

New Electric Service Company Dry Type Transformers are Guaranteed for a Period of five years from the date of shipment; to be free from defects in workmanship and materials under normal service. Normal service includes correct primary Voltage, Load, Frequency, Primary and Secondary Overvoltage and Current Protection, and Proper Installation.

Proper installation as defined under the conditions of this warranty includes sufficient air space around core and coil units for adequate convection cooling. Transformers purchased with Electric Service enclosures should be installed in such a manner that the air vents are not blocked by walls or equipment, etc. Purchaser's that install thermocouples and controls for fan cooling on Electric Service Transformers, must secure the thermocouple leads a minimum of six inches from the high voltage coils and Bus bar.

Any electrical or mechanical parts proving defective will be repaired or replaced (at our option) by us F.O.B. our plant. Correction of defects by repairing or replacing shall constitute fulfilling of our obligation to purchaser. We are not responsible for consequential losses or damages incurred for repairs or replacement made by others without our written authorization.

Electric Service Company